



**EUROPEAN UNION  
DELEGATION TO THE REPUBLIC OF SERBIA**

**CONTRACTING AUTHORITY'S CLARIFICATIONS No. 3**

**Project title:**

**Reconstruction of Judicial Academy Building in Belgrade**

**Publication reference: EuropeAid/139201/DD/WKS/RS**

No.	Question	Answer
1	<p>Please clarify us the manner of submitting the form – TENDER FORM (Volume 1, Section 2) in case of Joint Venture offer submission. Whether it is correct that this form be completed, signed and certified by leader of the consortium (Joint Venture), which is empowered, on behalf of all members to sign forms, submit a unique offer and represents the consortium in front of the Contracting Authority and other members sign and stamp the last page? Considering that the tender form contains a Tenderer's Declaration under point 3 where must state the local price, we think it is logic that the total value of the offer should be entered by the Leader of the Consortium and therefore certifies and signed this form by the Leader.</p>	<p>Please follow the instructions as stated in the Instructions to tenderers and in the Tender Form.</p> <p>The representative of the tenderer with a power of attorney should sign the Tender Form.</p> <p>However, as stated under Article 3 of the Tender form: "As part of their tender, each legal entity identified under point 1 of this form, including every consortium member, as well as each capacity-providing entity and each subcontractor providing more than 10% of the works, must submit a signed declaration using this format, together with the Declaration of honour on exclusion and selection criteria (Annex 1)."</p> <p>Yes, the total tender price should be mentioned in the declaration.</p>
2	<p>3.4.1.2.19. Air – water reversible Heat pumps</p> <p>Operating range for Heat pumps is specified to be from -25°C to 40°C. Most manufacturers are giving operating range from -20°C to 40°C. Please confirm this is acceptable.</p> <p>It is not clear from the Technical Specification is cuperheater part of the Heat pump or not. Please confirm.</p>	<p>Please see corrigendum no.1 published on 10/07/2018.</p>

3	<p>3.4.1.3. and 4. Air conditioning Unit for Server room – Type 1 and 2</p> <p>According to Technical Specification Type 1 and 2 Units are identical. Please confirm.</p>	<p>Please see corrigendum no.1 published on 10/07/2018.</p>
4	<p>3.4.1.3.9. Free-cooling air conditioning unit with IP 54 protection</p> <p>For Free-cooling Unit Technical Specification is not giving relevant technical data except additional equipment. Also it is not clear where the unit is positioned. Please explain</p>	<p>Please see corrigendum no.1 published on 10/07/2018.</p>
5	<p>We apologise, as we were not able to visit the site on the 8th of June, and so as to analyse the situation as best as possible, and participate in the procurement procedure, could you please organise another site visit? We will make ourselves available for any date which suits you.</p>	<p>No other site visit is planned for this tender procedure.</p>