EUROPEAN UNION
DELEGATION TO THE REPUBLIC OF SERBIA

CONTRACTING AUTHORITY'S CLARIFICATIONS No. 8

Project title:
Electrical equipment for the reaction in emergency situations

Publication reference: EuropeAid/137100/DH/SUP/RS

No.	Question	Answer
1.	We refer to the ITT under reference EuropeAid/137100/DH/SUP/RS, LOT 1: Supply of one (1) mobile electrical substation 110/35kV tender and noted some	

No.	Question	Answer
	discrepancies between the short-circuit ratings stipulated in Annex II, Section 2: Technical Specifications, Lot 1, Items 8.3.3 and Section 3: Technical Data Schedule, Items 2.28.1-6. After having reviewed both data, we are in the opinion that the values stipulated in Technical Specifications are correct and accordingly, Items 2.28.1-6 of the Technical Data Schedule should read as follows	Ratings should be as stipulated in Technical specification as follows:

2.28	Short circuit ratings		
2.28.1	Rated short time (2 sec) withstand current (primary winding)	kA	1.22
2.28.2	Rated peak short circuit current (primary winding)	kA	3.12
2.28.3	Rated short time (2 sec) withstand current (secondary winding)	kA	6.70
2.28.4	Rated peak short circuit current (secondary winding)	kA	17.10
2.28.5	Rated short time (2 sec) withstand current (tertiary winding)	kA	14
2.28.6	Rated peak short circuit current (tertiary winding)	kA	35.50

2.28	Short circuit ratings		
2.28.1	Rated short time (2 sec) withstand current (primary winding)	kA	1.22
2.28.2	Rated peak short circuit current (primary winding)	kA	3.12
2.28.3	Rated short time (2 sec) withstand current (secondary winding)	kA	6.70
2.28.4	Rated peak short circuit current (secondary winding)	kA	17.10
2.28.5	Rated short time (2 sec) withstand current (tertiary winding)	kA	14
2.28.6	Rated peak short circuit current (tertiary winding)	kA	35.50

<table>
<tr><th>No.</th><th>Question</th><th>Answer</th></tr>
<tr><td>2.</td><td>With regard to the On-Load Tap-Changer and in line with the short-circuit ratings stipulated in Annex II, Section 2: Technical Specifications, Lot 1, Items 8.3.3, we are in the opinion that Item 6.5 stipulated in Section 3: Technical Data Schedule, should read <u>Rated peak withstand current: 10kA</u>
<table>
<tr><td>6</td><td colspan="4">ON-LOAD TAP-CHANGER</td></tr>
<tr><td>6.1</td><td>Manufacturer</td><td></td><td></td><td></td></tr>
<tr><td>6.2</td><td>Type</td><td></td><td></td><td></td></tr>
<tr><td>6.3</td><td>Rated voltage</td><td>kV</td><td>123</td><td></td></tr>
<tr><td>6.4</td><td>Rated current</td><td>A</td><td></td><td></td></tr>
<tr><td>6.5</td><td>Rated peak withstand current</td><td>kA</td><td>10</td><td></td></tr>
<tr><td>6.6</td><td>Tap transition device type</td><td></td><td></td><td></td></tr>
<tr><td>6.7</td><td>Auxiliary power supply</td><td></td><td>400/230 V, 50 Hz</td><td></td></tr>
</table>
We look forward to receiving your clarification on the above matters for which we thank you very much in advance and remain for any further assistance you might require.</td><td>For the on-load tap changer, rated peak withstand current can be 10 kA, as follows:
<table>
<tr><td>6</td><td colspan="4">ON-LOAD TAP-CHANGER</td></tr>
<tr><td>6.1</td><td>Manufacturer</td><td></td><td></td><td></td></tr>
<tr><td>6.2</td><td>Type</td><td></td><td></td><td></td></tr>
<tr><td>6.3</td><td>Rated voltage</td><td>kV</td><td>123</td><td></td></tr>
<tr><td>6.4</td><td>Rated current</td><td>A</td><td></td><td></td></tr>
<tr><td>6.5</td><td>Rated peak withstand current</td><td>kA</td><td>10</td><td></td></tr>
<tr><td>6.6</td><td>Tap transition device type</td><td></td><td></td><td></td></tr>
<tr><td>6.7</td><td>Auxiliary power supply</td><td></td><td>400/230 V, 50 Hz</td><td></td></tr>
</table></td></tr>
</table>